



SEWER LATERAL & INSPECTION REQUIREMENTS

Sewer Lateral Requirements:

- Single/Independent Lateral per Dwelling
- PVC, ABS, or HDPE Pipe Material
- Min. Pipe Diameter of 4-inches
- Min. Cover of 3ft. (Property Line)
- Sewer Relief Valve (SRV) per Dwelling
- Cleanouts at 100ft Intervals
- Connection to Manholes Not permitted
- Connection to Interceptors Not Permitted
- Sewer Lateral to Sewer Main Connection Shall be Made by PBCSD Staff Only

Inspections Requirements:

- It is the Owner/Contractor's responsibility to contact PBCSD to schedule inspection for ALL repairs, improvements, and replacement of sewer service laterals and/or appurtenances PRIOR to backfill. Failure to do so shall require the Owner/Contractor to excavate and expose improvements so that they can be inspected and approved by PBCSD staff.
- When trenchless technology is utilized Owner/Contractor is required to camera new sewer lateral via CCTV in the presence of PBCSD staff.
- Owner/Contractor is required to notify PBCSD of inspection request a minimum of 24hrs in advance of desired date of inspection. Please call (831) 647-5620 or (831) 760-0224 to schedule an inspection.